



Pimpri Chinchwad Municipal Corporation

Pimpri, Pune - 411018.

Phone :- 020- 67331110/1120

Fax :- 020- 27425600

E-Mail :- commissioner@pcmcindia.gov.in

Web :- www.pcmcindia.gov.in

NO - ws/lab/1485/2022

Date - 03/12/2022

To,

The Principal,

Camp Education Society's Motilal Talera English Medium School,

Moshi, Pune.

Subject: Water sample Potability Certificate.

Drinking water sample provided by Camp Education Society's Motilal Talera English Medium School, Moshi, Pune on Date: 01/12/2022 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /1479/2022 dated 02/12/2022 & ws /lab /1483/2022 dated 02/12/2022 the water Sample is safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory.

Chief Chemist

Pimpri Chinchwad Municipal Corporation

Pimpri -18

**Principal
Motilal Talera
English Medium School
Moshi, Pune - 412 105.**

**Manager
Motilal Talera
English Medium School
Moshi, Pune - 412 105.**

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION



Report Of Chemical Examination Of Water

NO-WS / LAB / 1477/2022.

DATE - 02 / 12 / 2022.

NAME - कॅम्प राज्युकेशन सोसायटी मोतीलाल तालेरा
ADDRESS - मोशी, इंग्लिश मिडीयम स्कूल

DATE OF RECEIPT - 01 / 12 / 2022.

DATE OF EXAMINATION - 02 / 12 / 2022.

SOURCE - PCMC Water.

NO	TESTS	I.S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N.T.U Max	0.19 NTU.		
2	pH	6.5 to 8.5	7.37.		
3	Total Hardness (as CaCO ₃)	200 mg/lit	32 mg/lit		
4	Chloride	250 mg/lit	12 mg/lit		
5	Calcium	75 mg/lit	6.01 mg/lit		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

CHIEF CHEMIST

Water treatment plant
sector 23 Nigdi

Principal

Motilal Talera
English Medium School
Moshi, Pune - 412 105

Manager

Motilal Talera
English Medium School
Moshi, Pune - 412 105.

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(w/s) DIVISION



No-WS/LAB/1483/2022.

Date- 02 / 12 / 2022.


REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

NAME- कैम्प राड्युलेशन ओसायटी मोनिलाल तालेरा DATE OF EXAMINATION-01 / 12 / 2022.


ADDRESS- मोशी. इंग्लिश मिडियम स्कूल.

SOURCE - PCMC Water.

NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUTION MPN/100ml		REMARK
			Coliforms	E.Coil	
1	Water Sample.	Nil.	0/100ml	-	Potable.
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44


Principal
Motilal Talera
English Medium School
Moshi, Pune - 412 105.


Manager
Motilal Talera
English Medium School
Moshi, Pune - 412 105.